



- NOTES:**
- A. ALL DIMENSIONS IN MILLIMETERS UNLESS OTHERWISE SPECIFIED.
 - B. BEARING SURFACE TO BE MACHINED.
 - C. PERFORMANCE WITH CSA C83 ITEM M-2 750mm MANHOLE FRAME.
 - D. FRAME SHALL BE COATED.
 - E. (4) 11/16" DIA. HOLES ON 40.5" DIA. (1033mm) BOLT CIRCLE.
 - F. 13mm DIA. (1/2") TAPPED HOLE THRU FLANGE.
 - G. BURNDY KC26 SERVIT POST CONNECTOR. PENTROX INHIBITOR TO BE APPLIED TO BOTH THE THREADS OF THE HOLE AND THE KC26 SERVIT POST BURNDY CONNECTOR BY OTHERS.
 - H. LIFTING LUG (4 REQUIRED,) TO BE LOCATED SYMMETRICALLY.
 - I. ✓ DESIGNATES MACHINED SURFACE.

REVISIONS		PREP	CHKD	APPD	TITLE	
REV: 3	DATE: 2007-05-02	FB	RW	CSM	ENGINEERING SPECIFICATION	
CHANGE:	TITLE CHANGE					
REV: 4	DATE: 2012-02-29	FB	RW	CSM	MANHOLE HARDWARE FRAME	
CHANGE:	ADDED GROUND DETAIL, NOTE 'D'				CONSTRUCTION DETAIL	
REV: 5	DATE: 2017-03-15	MBW	RW	CSM	NO:	
CHANGE:	COMPLETE REVISION				UCS0020	
					1	REV: 1
					1	5

