

NOTES:

- A. ALL DIMENSIONS IN MILLIMETERS UNLESS OTHERWISE SPECIFIED.
- B. APPLICABLE FOR 100mm DIAMETER DUCTS.
- C. DUCT ROLL NOT TO EXCEED ONE RADIAL POSITION OVER THE MINIMUM TRANSPOSITION LENGTH.





FIG. 1





FIG. 2

TYPICAL MINIMUM TRANSPOSITION LENGTH FOR CHANGING FORMATION OF 100mm DIAMETER DUCTS:

FIG. 1 7500mm

FIG. 2 6000mm

REV: CHANGE:	DATE: YYYY-MM-DD	PREP	CHKD	APPD	TITLE	NO:	REV:		
REV: CHANGE:	DATE: YYYY-MM-DD				 <p>HydroOttawa www.hydroottawa.com</p>	<p>ENGINEERING SPECIFICATION DUCT TRANSPOSITION FROM 1H X 6W TO 2H X 3W CONSTRUCTION DETAIL</p>	<p>UDS0033</p>		
REV: CHANGE:	DATE: YYYY-MM-DD								
REV: CHANGE:	DATE: YYYY-MM-DD								
REV: CHANGE:	DATE: YYYY-MM-DD								
<p>PREP: M. MALONEY CHKD: C. PROULX APPD: C. MALONE DATE: 2015-06-26 SCALE: N.T.S. @ ANSIA</p>					<p>1 OF 1 REV: 0</p>				

For Hydro Ottawa Use Only Copyright 2015