

POLE ATTACHMENTS FIELD CONSIDERATIONS

ONTARIO ENERGY BOARD


IN THE MATTER OF the Ontario Energy Board Act, 1998, S.O. 1998, c. 15, Schedule B;

AND IN THE MATTER OF an Application by Hydro Ottawa Limited for an Order approving rates and other service charges for the distribution of electricity for the years 2016 through 2020.

CONTENT


- ANATOMY OF A 40' POWER POLE
- TECHNICAL SAFETY
- FIELD IDENTIFICATION
- TELECOM ATTACHMENTS ILLUSTRATIONS
- FIELD ACTIVITIES

Anatomy of a 40' Power Pole



TECHNICAL SAFETY


- Ontario Regulation 22/04 defines the safety requirements with and around electrical distribution systems
- Main physical criteria for safety are:
 - Clearance
 - Strength
 - Grounding
- The LDC is ultimately responsible to ensure the attachers comply with these requirements



TECHNICAL SAFETY TELECOM APPLICATION ON POLES

SUPPORT STRAND REQUIRES GROUNDING





FIELD IDENTIFICATION




Total number of current telecom attachers @ OEB rate = 43,543

Total number of current telecom attachments = 78,688

Note – there are an additional 13,265 Streetlight attachments @ OEB rate

TELECOM ATTACHMENTS - ILLUSTRATIONS OVERLASH TO ITSELF




ROGERS HAS: 10 CABLE ATTACHMENTS ON

2 SUPPORT STRANDS AND

1 ANNUAL ATTACHER PAYMENT



TELECOM ATTACHMENTS - ILLUSTRATIONS OVERLASH TO 3RD PARTIES




TELUS OVERLASHED TO ROGERS' UPPER SUPPORT STRAND

ALLSTREAM
OVERLASHED TO
ROGERS' LOWER
SUPPORT STRAND

3 ATTACHERS HAVE
7 CABLE ATTACHMENTS AND
CABLE DIPS DOWN THE
POLE

TELECOM ATTACHMENTS - ILLUSTRATIONS SERVICE DROPS TO ADJACENT BUILDINGS



TELECOM
SERVICE DROPS
CONNECT
BUILDINGS TO
MAIN NETWORK
CABLES


FIELD ACTIVITIES DELAYED TRANSFERS



TELECOM DELAYED
TRANSFER REQUIRES
POLE OWNER TO
RETURN TO REMOVE
ITS POLE AND
RE-INSTATE



FIELD ACTIVITIES DELAYED TRANSFERS TYPICAL TIMELINE WITH PLANNED POLE REPLACEMENT



		*.