



NOTES:

- A. ALL DIMENSIONS ARE IN MILLIMETERS, UNLESS OTHERWISE SPECIFIED.
- B. INSTALLATION FOR "FLAT RATE" METERING ARRANGEMENT ONLY.
- C. SEE STANDARDS ECS0017 AND OLS0001 FOR POLE MOUNTING PROFILE.
- D. ESA INSPECTION AND APPROVAL REQUIRED WHEN NOT OWNED BY HYDRO OTTAWA.
- E. SECONDARY BUS IS BELOW THE TRANSFORMER. IF ABOVE, HYDRO OTTAWA TO INSTALL.

For Hydro Ottawa Use Only Copyright (c) 2014

2014-09-15 12:55:24 PM

REVISIONS		PREP	CHKD	APPD
REV:	DATE:	SK	SMC	CSM
1	2014-09-03			
CHANGE: UPDATE NOTES DIMENSIONS AND STANDARDIZE FONTS				

HydroOttawa
WWW.HYDROOTTAWA.COM

PREP: G. MOLNAR
CHKD: C. PROULX
APPD: C. MALONE P.Eng.
DATE: 2008-03-31
SCALE: N.T.S. @ ANSIA

TITLE		ENGINEERING SPECIFICATION	
		15A @ 120V RECEPTACLE ON UTILITY POLE FOR OCCASIONAL USE DECORATIVE LIGHTING CONSTRUCTION DETAIL	
NO:	ECS0027	REV:	1
		OF	1