



SPECIFICATIONS-
 FAULT CURRENT: 30,000 AMPERES FOR 30 CYCLES
 GROUNDED STUD MATERIAL: CU/Al OR BRONZE

NOTE:

A. ALL DIMENSIONS IN MILLIMETERS UNLESS INDICATED OTHERWISE.

\$ TIME \$
\$ DATE \$
\$ FILE \$

REVISIONS			PREP	CHKD	APPD	TITLE	
REV: 1	DATE: 2007-08-27	GM	CP	CSM	 WWW.HYDRO-OTTAWA.COM		ENGINEERING SPECIFICATION
CHANGE:	NOTE ADDED						GROUNING STUD
REV:	DATE: YYYY-MM-DD						CONSTRUCTION DETAIL
CHANGE:					APPD: G. MOLNAR	NO: EGS0001	1
REV:	DATE: YYYY-MM-DD				CHKD: G. MACILL		OF
CHANGE:					APPD: C. MALONE P.Eng.		1
					DATE: 2002-04-04		REV: 1
					SCALE: 1:1 ANSIA		