



**NOTES:**

- A. FOR CENTRAL METERING (CM) DETAILS REFER TO HYDRO OTTAWA REVENUE METERING SPECIFICATION GCS0008, TABLE 3.
- B. THE 3-WIRE CURRENT TRANSFORMER AND METER SHALL BE SUPPLIED AND INSTALLED BY HYDRO OTTAWA METERING SERVICES.
- C. ALL DIMENSIONS ARE IN MILLIMETERS, UNLESS OTHERWISE SPECIFIED.
- D. MINIMUM OF 1000 [3' 4"] OF CLEARANCE REQUIRED IN FRONT OF ALL ELECTRICAL AND REVENUE METERING EQUIPMENT IF INSTALLED AT OUTDOOR LOCATION; MINIMUM OF 1500 [5'] OF CLEARANCE REQUIRED IF INSTALLED AT INDOOR LOCATION.
- E. RIGID SCHEDULE 80 PVC CONDUIT TO BE USED IF INSTALLED IN OUTDOOR LOCATION; EMT CONDUIT USED IF INSTALLED IN INDOOR LOCATION. PVC EXPANSION COUPLINGS USED AS PER ONTARIO ELECTRICAL SAFETY CODE (OESC).

REV.	DATE	BY	CHKD	APPD	TITLE
REV: 2	DATE: 2008-03-20	CM	KH	CSM	<p><b>HydroOttawa</b> www.hydroottawa.com</p> <p>PREP: G. MOLNAR CHKD: B. PECK APPD: C. MALONE DATE: 2003-07-22 SCALE: N.T.S. &amp; ANSIA</p> <p>NO: <b>MCS0004</b></p> <p><b>ENGINEERING SPECIFICATION</b> AGR OH 120V/240V 1PH, 3W, 400A TRANSFORMER RATED SERVICE WITH WEATHERPROOF COMBINATION METER SOCKET BASE CONSTRUCTION DETAIL</p>
CHANGE: GCS0008	SECTION CHANGED				
REV: 3	DATE: 2014-09-03	SK	SMC	CSM	
CHANGE: GENERAL	UPDATE				
REV: 4	DATE: 2016-02-05	JD	SMC	CSM	
CHANGE: UPDATE	TITLE				

For Hydro Ottawa Use Only Copyright 2016

1	REV:
1	4