


NOTES:

- A. FOR INSTALLATION REQUIREMENTS REFER TO HYDRO OTTAWA REVENUE METERING SPECIFICATION DOCUMENT GCS0008, TABLE 4.
- B. ALL DIMENSIONS ARE IN MILLIMETERS, UNLESS OTHERWISE SPECIFIED.
- C. MINIMUM OF 1500 [5'] CLEARANCE REQUIRED IN FRONT OF ALL METERING EQUIPMENT.
- D. THE 3-WIRE CURRENT TRANSFORMER AND METER SHALL BE SUPPLIED AND INSTALLED BY HYDRO OTTAWA METERING SERVICES.

REV.:	DATE:	PREP:	CHKD:	APPD:	TITLE:
REV: 2 CHANGE:	DATE: 2008-03-19	GM	KH	CSM	 HydroOttawa www.hydroottawa.com
REV: 3 CHANGE:	DATE: 2014-09-03	SK	SMC	CSM	
REV: 4 CHANGE:	DATE: 2016-01-13	JD	SMC	CSM	
CHANGE: UPDATE TITLE					
PREP: F. BOLO CHKD: B. PECK APPD: C. MALONE DATE: 2003-07-22 SCALE: N.T.S. & ANSIA					ENGINEERING SPECIFICATION COM 120V/240V 1PH, 3W, 400A TRANSFORMER RATED SERVICE USING METER SOCKET WITH SEPARATE INSTRUMENT TRANSFORMER CABINET CONSTRUCTION DETAIL
NO: MCS0007					1 REV: 4 OF 1