



NOTES:

- A. REFER TO HYDRO OTTAWA REVENUE METERING SPECIFICATION GCS0008, METAL ENCLOSED SWITCHGEAR REQUIRED.
- B. ALL DIMENSIONS ARE IN MILLIMETERS, UNLESS OTHERWISE SPECIFIED.
- C. MINIMUM CLEARANCE OF 1500 [5'] REQUIRED IN FRONT OF ALL METERING EQUIPMENT.
- D. REFER TO HYDRO OTTAWA REVENUE METERING SPECIFICATION GCS0008, TABLE 5A, FOR LIST OF APPROVED 13-JAW TRANSFORMER RATED METER SOCKET BASES.
- E. PLYWOOD MOUNTING SURFACE PAINTED WITH GRAY FIRE RETARDANT PAINT. MEASURING 900 X 900 X 16 [36"] X 36" X 5/8", OR 900 X 900 X 19 [36"] X 36" X 3/4", EXCLUSIVELY FOR 13-JAW TRANSFORMER RATED METER SOCKET BASE, AND HYDRO OTTAWA METERING EQUIPMENT.
- F. EXTERNAL MODEM ENCLOSURE REQUIRED FOR 120V/208Y 800A (OR GREATER) OR 347V/600Y GREATER THAN 200A SERVICES. REFER TO HYDRO OTTAWA SPECIFICATION MCS0066 FOR MORE INFORMATION.

REV. NO.	DATE	BY	CHKD	APPD	TITLE
REV. 2	DATE: 2008-03-19	CM	KH	CSM	<p>HydroOttawa www.hydroottawa.com</p> <p>ENGINEERING SPECIFICATION COM/RES 120V/208Y OR 347V/600Y, 3PH 4W NON-INTERVAL METERING ARRANGEMENT IN A SWITCHBOARD WITH PEAK DEMAND ≤ 233kW CONSTRUCTION DETAIL</p>
CHANGE:	GCS0008 SECTION CHANGED				
REV. 3	DATE: 2014-09-03	SK	SMC	CSM	
CHANGE:	UPDATE NOTES AND DIMENSIONS				
REV. 4	DATE: 2016-01-13	JD	SMC	CSM	
CHANGE:	ADDED NOTE 'F' AND UPDATE TITLE				
<p>PREP: F. BOLO CHKD: B. PECK</p> <p>APPD: C. MALONE DATE: 2003-07-22 SCALE: N.T.S. & ANSIA</p>					
<p>NO: MCS0024</p>					
<p>REV: 1 OF 1</p>					REV: 4