


- NOTES:**
- A. THE METER SOCKET BASE SHALL BE A HYDRO OTTAWA APPROVED 20A, 600V, TRANSFORMER RATED SELF-SHORTING 5-JAW METER SOCKET BASE WITH PROVISION FOR METER TEST SWITCH APPROVED BY HYDRO OTTAWA. REFER TO HYDRO OTTAWA REVENUE METERING SPECIFICATION GCS0008, TABLE 4.
 - B. FOR LIST OF APPROVED METER SOCKET BASES AND ENCLOSURES, REFER TO HYDRO OTTAWA REVENUE METERING SPECIFICATION GCS0008.
 - C. ALL DIMENSIONS ARE IN MILLIMETERS, UNLESS OTHERWISE SPECIFIED.
 - D. MINIMUM OF 1000 [3' 4"] OF CLEARANCE REQUIRED IN FRONT OF ALL ELECTRICAL AND REVENUE METERING EQUIPMENT IF INSTALLED AT OUTDOOR LOCATION; MINIMUM OF 1500 [5'] OF CLEARANCE REQUIRED IF INSTALLED AT INDOOR LOCATION.
 - E. RIGID SCHEDULE 80 PVC CONDUIT TO BE USED IF INSTALLED IN OUTDOOR LOCATION; EMT USED IF INSTALLED IN INDOOR LOCATION. PVC EXPANSION COUPLINGS USED AS PER ONTARIO ELECTRICAL SAFETY CODE (O.E.S.C.).

REV. NO.	DATE	BY	CHKD.	APPD.	TITLE
REV. 2	DATE: 2008-03-20	GM	KH	CSM	 HydroOttawa www.hydroottawa.com ENGINEERING SPECIFICATION COM UG 120V/240V, 1PH, 3W, 400A SERVICE WITH SWITCHBOARD CONSTRUCTION DETAIL
CHANGE:	GCS0008 SECTION CHANGED				
REV. 3	DATE: 2014-09-03	SK	SMC	CSM	
CHANGE:	UPDATE NOTES AND DIMENSIONS				
REV. 4	DATE: 2016-02-05	JD	SMC	CSM	
CHANGE:	UPDATE TITLE AND NOTES				
PREP: F. BOLD CHKD: B. PECK APPD: C. MALONE DATE: 2003-07-22 SCALE: N.T.S. @ ANSIA					NO: MCS0042
					1 OF 1 REV: 4