


NOTES:

- A. FOR INSTALLATION REQUIREMENTS REFER TO HYDRO OTTAWA REVENUE METERING SPECIFICATION DOCUMENT GCS0008, TABLE 4.
- B. ALL DIMENSIONS ARE IN MILLIMETERS, UNLESS OTHERWISE SPECIFIED.
- C. MINIMUM OF 1500 [5'] OF CLEARANCE REQUIRED IN FRONT OF ALL ELECTRICAL AND REVENUE METERING EQUIPMENT IF INSTALLED AT OUTDOOR LOCATION; MINIMUM OF 1500 [5'] OF CLEARANCE REQUIRED IF INSTALLED AT INDOOR LOCATION.
- D. THE 3-WIRE CURRENT TRANSFORMER AND METER SHALL BE SUPPLIED AND INSTALLED BY HYDRO OTTAWA METERING SERVICES.

REVISONS	PREP	CHKD	APPD	TITLE
DATE	JD	SMC	CSM	
REV: 1 CHANGE: UPDATE TITLE				 <p>www.hydroottawa.com</p> <p>ENGINEERING SPECIFICATION COM 120V/240V 1PH, 3W, 400A TO 600A TRANSFORMER RATED SECONDARY SERVICE WITH OFFSET METER SOCKET CONSTRUCTION DETAIL</p>
REV: CHANGE:				
REV: CHANGE:				
REV: CHANGE:				
PREP: M. MALONEY				<p>NO: MCS0092</p> <p>1 OF 1 REV: 1</p>
CHKD: S. McNALLY (E.L.T.)				
APPD: C. MALONE P.Eng.				
DATE: 2014-11-07 SCALE: N.T.S. @ ANSIA				