


**INSTALLATION PROCEDURES:**

- A. OUTDOOR PADMOUNTED TRANSFORMERS SHALL BE LOCATED/INSTALLED AS PER THE ONTARIO ELECTRICAL SAFETY CODE, SECTION 26-242.
- B. NO PLANTS OR FIRE HYDRANTS SHALL BE INSTALLED WITHIN 3M [10'] OF TRANSFORMERS.
- C. ALL WORK SHALL BE INSPECTED BY HYDRO OTTAWA PRIOR TO BACKFILLING. CONTRACTOR IS RESPONSIBLE FOR CONDUCTING COMPACTION TESTS BY A QUALIFIED TESTING AGENCY AND PROVIDING TEST RESULTS TO HYDRO OTTAWA.
- D. IF BOLLARDS ARE REQUIRED EXTEND COMPACTED BASE TO 1000mm FROM WALL. IF BOLLARDS ARE NOT REQUIRED EXTEND COMPACTED BASE 300mm FROM WALL.
- E. ALL MEASUREMENTS IN MILLIMETERS UNLESS OTHERWISE INDICATED.

6/3/2010 9:08:39 AM

REVISIONS				PREP	CHKD	APPD	TITLE						
REV: 1	DATE: 2003-02-19	MG	CP	CSM	 WWW.HYDRO-OTTAWA.COM	<b>ENGINEERING SPECIFICATION</b> <b>TRANSFORMER OR SWITCHGEAR</b> <b>BASE &amp; PAD</b> <b>CONSTRUCTION DETAIL</b>							
CHANGE: REVISED INSTALLATION PROCEDURES NOTE MEET OESC 2002													
REV: 2	DATE: 2007-08-27	CP	CP	CSM									
CHANGE: NOTES LAYOUT					PREP: G. GOFORTH	NO: <b>UCS0004</b>							
					CHKD: C. PROULX								
REV: 3	DATE: 2010-05-27	FB	RW	CSM	APPD: C. MALONE P.Eng.								
CHANGE: TITLE CHANGE					DATE: 2002-01-29	<table border="1"> <tr> <td>1</td> <td>REV:</td> </tr> <tr> <td>OF</td> <td>3</td> </tr> <tr> <td>1</td> <td></td> </tr> </table>		1	REV:	OF	3	1	
1	REV:												
OF	3												
1													
					SCALE: N.T.S. @ ANSIA								