



FIG 1. TYPICAL CONCRETE DUCT BANK SECTION VIEW

NOTES:

- A. FOR RESIDENTIAL SERVICE ONLY.
- B. NOT APPLICABLE FOR CROSSING AT TRANSFORMERS.
- C. ALL BACKFILL MATERIAL MUST BE APPROVED BY HYDRO OTTAWA INSPECTOR. FOR ACCEPTABLE BACKFILL MATERIAL, SEE HYDRO OTTAWA SPECIFICATION DOCUMENT GCS0005 SECTION 7.0.
- D. ALL UNITS IN MILLIMETERS UNLESS OTHERWISE NOTED.

Hydro Ottawa Use Only

\$ TIME \$	REVISIONS			PREP	CHKD	APPD	 WWW.HYDRO-OTTAWA.COM	TITLE ENGINEERING SPECIFICATION FOUR PARTY RESIDENTIAL ROAD CROSSING CONCRETE DUCT BANK CONSTRUCTION DETAIL						
	REV: CHANGE:	DATE: YYYY-MM-DD									PREP: G.MOLNAR	NO:	1 OF 1	REV: 0
	REV: CHANGE:	DATE: YYYY-MM-DD									CHKD: K. McROBERTS			
REV: CHANGE:	DATE: YYYY-MM-DD					APPD: C. MALONE P. Eng	UDS0024							
\$ DATE \$							DATE: 2007-07-03							
							SCALE: N.T.S. @ ANSIA							
\$ FILE \$														