

NOTES:

- A. ALL DIMENSIONS IN MILLIMETERS UNLESS OTHERWISE SPECIFIED.
- B. APPLICABLE FOR 100mm DIAMETER DUCTS.
- C. DUCT ROLL NOT TO EXCEED ONE RADIAL POSITION OVER THE MINIMUM TRANSPOSITION LENGTH.





FIG. 1






FIG. 2

TYPICAL MINIMUM TRANSPOSITION LENGTH FOR CHANGING FORMATION OF 100mm DIAMETER DUCTS:

FIG. 1 7500mm

FIG. 2 6000mm

REV: CHANGE:	DATE: YYYY-MM-DD	PREP	CHKD	APPD	TITLE	NO:	REV:	
REV: CHANGE:	DATE: YYYY-MM-DD				 HydroOttawa www.hydroottawa.com	ENGINEERING SPECIFICATION DUCT TRANSPOSITION FROM 1H X 6W TO 2H X 3W CONSTRUCTION DETAIL	1	
REV: CHANGE:	DATE: YYYY-MM-DD							0
REV: CHANGE:	DATE: YYYY-MM-DD							

PREP: M. MALONEY	
CHKD: C. PROULX	
APPD: C. MALONE	P.Eng.
DATE: 2015-06-26	
SCALE: N.T.S. @ ANSIA	

UDS0033		1	REV:
		OF	
		1	0

For Hydro Ottawa Use Only Copyright 2015